
KANNUR UNIVERSITY
(Planning and Development Branch)
NOTICE INVITING RE-QUOTATIONS

PLD/E3/9409/2020 Part I

01.08.2023


Sealed competitive Quotations Super scribed as "Electrical works at Mangattuparamba Campus of Kannur University" are invited from registered competent Electrical Contractors/firms.

Quotations with all details should reach the office of the Registrar, Kannur University, Kannur -02 on or before 16-8-23 at 3pm and the quotations will be opened at 3.30pm on the same day.

Conditions:

1. The rate quoted should be inclusive of GST and all other charges if any. The base rate, GST charges and other charges if any should be furnished separately and nothing extra shall be admissible over and above the rate quoted.
2. The Contractor shall arrange all material & equipment and should be got approved by the Executive Engineer and work shall be executed as per KPWD specifications.
3. Payment will be made the through bank account and no advance payment will be sanctioned.
4. Work shall be completed within 30 days from the date of Agreement.
5. Quotation forms and details of works can be had from the www.kannuruniv.ac.in.

The Registrar, Kannur University reserves the right to reject any of the quotations or all the quotations without assigning any reason whatsoever.



Dr. Joby K Jose
REGISTRAR (i/c)



KANNUR UNIVERSITY

QUOTATION SCHEDULE

NAME OF THE WORK: Electrical works at Mangattuparamba campus

LAST DATE OF SUBMISSION: 16/08/2023

SL NO	QUANTITY	ITEM DESCRIPTION	UNIT	RATE INCLUDING ALL TAXES		AMOUNT	REMARKS
				RATE IN FIGURES	RATE IN WORDS		
		PART A					
1	2	Supply, conveyance and fixing the following types & current rated control gears & switchgears conforming to IS 13947 suitable for 440 V, 50 Hz, AC supply in the existing panel assembly as required. 125A, 35/36 kA (lcs=100%lcu), 4 pole, current limiting type MCCB with microprocessor based release with overload setting of 50 - 100% having adjustable OL & SC	nos				
2	1	Supply, conveyance and fixing the following types & current rated control gears & switchgears conforming to IS 13947 suitable for 440 V, 50 Hz, AC supply in the existing panel assembly as required. 125A, 35/36 kA (lcs=100%lcu), 3 pole, current limiting type MCCB with microprocessor based release with overload setting of 50 - 100% having adjustable OL & SC	no				
3	2	Supply, conveyance and fixing the following types & current rated control gears & switchgears conforming to IS 13947 suitable for 440 V, 50 Hz, AC supply in the existing panel assembly as required. 16 A-100A, 25/35 kA (lcs=100%lcu), 3 pole, current limiting type MCCB having thermal setting range of 80 - 100% with thermal magnetic release having adjustable OL	nos				
4	2	Supply, conveyance and fixing the following types & current rated control gears & switchgears conforming to IS 13947 suitable for 440 V, 50 Hz, AC supply in the existing panel assembly as required. 16 A-100A, 16 kA (lcs=100%lcu), 4 pole, current limiting type MCCB having thermal setting range of 80 - 100% with thermal magnetic release having adjustable OL	nos				

SL NO	QUANTITY	ITEM DESCRIPTION	UNIT	RATE INCLUDING ALL TAXES		AMOUNT	REMARKS
				RATE IN FIGURES	RATE IN WORDS		
5	3	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole	nos				
6	2	Supplying and fixing following rating, double pole, (single phase and neutral), 240 V, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required. 25 amps	nos				
7	2	Supplying and fixing following rating, four pole, (three phase and neutral), 415 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required. 40 amps	nos				
		PART B					
1	1	Supplying and making straight through joint with cast resin compound including ferrules and other jointing materials for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required. 4 X 35 sq. mm	each				
		TOTAL					

*Rate including GST

(Rupees Only)

SIGNATURE

Name & Address of the Quotationer

Date