

PLANNING AND DEVELOPMENT BRANCH

NOTICE INVITING QUOTATIONS

PLD/E1/22502/2025

09.06.2026

Sealed competitive Quotations super scribed as " **Electrical works at Kasaragod Campus of Kannur University**" are invited from registered competent electrical Contractors/firms.

Quotations with all details should reach the office of the Registrar, Kannur University, Kannur-2 on or before 24/06/2026 at 3.00 pm and the Quotations will be opened at 3.30 pm on the same day.

Conditions:

1. The rate quoted should be **inclusive of GST and all other charges if any**. The base rate, GST charges and other charges if any should be furnished separately and nothing extra shall be admissible over and above the rate quoted.
2. The Contractor shall arrange suitable materials and equipment and should be got approved by the Assistant Executive Engineer and work shall be executed as per KPWD specifications.
3. The Payment will be made through bank account and no advance payment will be sanctioned.
4. The successful bidder will be required to deposit Performance Guarantee/Security Deposit as per rules.
5. Work shall be completed within **1 Month** from the date of agreement.
6. A defect liability period of 1 year after completion of the work will be applicable.
7. Quotation forms and details of works can be had from the [www.kannuruniv.ac.in](http://www.kannuruniv.ac.in).
8. The Registrar, Kannur University reserves the right to reject any of the quotations or all the quotations without assigning any reason whatsoever.
9. Quotation schedule is appended herewith.

*sd/-*

Registrar

To

1. Notice Board
2. Website



**KANNUR UNIVERSITY**

**QUOTATION SCHEDULE FOR KUTEC KASARAGOD CAMPUS-ELECTRICAL WORK**

LAST DATE OF SUBMISSION:

Sl. NO	ITEM DESCRIPTION	UNIT	QUANTITY	RATE IN FIGURES	RATE IN WORDS	AMOUNT	REMARKS
1	19.1 Supply, installation, testing and commissioning of 1200 mm sweep BEE-5 star rated ceiling fan with brushless direct current motor (BLDC), class of insulation B, 3 nos; blades, 30 cm long down rod, 2 nos; canopies, shackle kit, safety rope, copper winding, power factor not less than .9, service value (CM/M/W) minimum 6.00, Air delivery minimum 210 cum/min, 350 RPM (tolerance as per IS :374-2019, THD less than 10% remote or electronic regulator unit for speed control and all remaining accessories including safety pin, nut and bolts, washers, temperature rise equal to 75 deg celsius ( maximum ), insulation resistance more than 2 Megaohm, suitable for 230V, 50 Hz, single phase AC supply, earthing etc., complete as required.	Nos	20				
2	2.10.3 Supplying and fixing 5A to 32A rating, 240/415 volts, 10kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing DB complete with connections, testing and commissioning etc. as required. Double pole	Nos	12				
3	OD257099/2025-2026 Supply of commercial batten type integrated LED light fitting having color temperature not less than 5700K, system lumen output not less than 2000 and system wattage not more than 20 W, CRI not less than 80, extruded polycarbonate housing with PC diffuser, in-built electronic driver with surge protection not less than 2 kV etc. as required.	Nos	20				
<b>TOTAL AMOUNT</b>							
<b>GST 18%</b>							
<b>GRAND TOTAL</b>							
(Rupees .....Only)							
<b>SIGNATURE</b>						<b>REGISTRAR</b>	
<b>Name &amp; Address of the of the Quotationer</b>							
<b>Date</b>							