

PLD/E-4/15555/2024

25.07.2025

Ref : Quotation Notice No. PLD/E-4/15555/2024 dated 10.07.2025

Quotation for " Wiring required to install air conditioner in seminar hall of the Department of Mathematical Sciences , Mangattuparamba Campus" Last date of receiving quotation-extended -reg

The last date for receiving of quotation for " Wiring required to install air conditioner in seminar hall of the Department of Mathematical Sciences , Mangattuparamba Campus" is extended till 02.08.2025 at 3.00 PM, Time of opening- 3.30 PM



REGISTRAR

KANNUR UNIVERSITY
(Planning and Development Branch)
NOTICE INVITING QUOTATIONS

PLD/E-4/15555/2024

10.07.2025

Sealed competitive Quotations Super scribed as " Wiring required to install air conditioner in seminar hall of the Department of Mathematical Sciences, Mangattuparamba Campus" are invited from registered competent Contractors/firms.

Quotations with all details should reach the office of the Registrar, Kannur University, Kannur - 02 on or before ~~25.07.~~2025 at 3 pm and the quotations will be opened at 3.30 pm on the same day.

Conditions:

1. The rate quoted should be inclusive of GST and all other charges if any. The base rate, GST charges and other charges if any should be furnished separately and nothing extra shall be admissible over and above the rate quoted
2. The contractor shall arrange all material & equipment and should be got approved by the Registrar on recommendations of the Engineer in charge and work shall be executed as per KPWD specifications.
3. The Payment will be made the through bank account and no advance payment will be sanctioned
4. Work shall be completed within 30 days from the date of Agreement.
5. The Engineer in Charge shall be Assistant Engineer (Electrical).
6. The defect Liability period shall be 18 months from the date of completion of the work. and the contractor shall be responsible to maintain all his works till completion.
7. Successful Quotationer shall deposit a sum equivalent to 5% of value of contract as Security Deposit within the period specified in the Work order.
8. The quotationer, before submitting the quotation for the work shall ensure that, the quotationer visited the Site and satisfied himself about the site conditions for the works (including arranging facilities of water and electricity) and for logistics and smooth flow of workmen, and materials as well as permission from Authorities for this purpose
9. The Contractor shall make his own arrangements of Water and Electricity.
10. Quotation forms and details of works can be had from the www.kannuruniv.ac.in.
11. Quotation Schedule is appended.

The Registrar, Kannur University reserves the right to reject any of the quotations or all the quotations without assigning any reason whatsoever.



Prof. (Dr.) Joby K Jose
Registrar



Quotation schedule for the wiring required to install the AC in Seminar hall (Mathematical science) at Mangattuparambu campus

LAST DATE OF SUBMISSION: 02.08.2025							
SL. NO	ITEM DESCRIPTION	UNIT	QTY	RATE IN FIGURES	RATE IN WORDS	AMOUNT	REMARKS
	Wiring						
1	Item code-1.17.31 Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel/ PVC conduit as required. 4 x 6 sq. Mm	Mtr	41				
2	Item code-1.17.21 Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel/ PVC conduit as required. 3 x 4 sq. Mm	Mtr	2				
3	Item code-1.21.1 Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/ recess including cutting the wall and making good the same in case of recessed conduit as required. 20 mm	Mtr	23				

4	Item code-1.21.1 Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/ recess including cutting the wall and making good the same in case of recessed conduit as required. 25 mm	Mtr	37					
5	Item code-1.24.5 Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 6 pin 15/16 amp socket outlet	Nos	2					
6	Item code-1.24.3 Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 15/16 amp switch	Nos	2					
7	Item code-90.10.1.2 Supply & Fixing the following types/ sizes of boxes suitable for modular accessories in surface/ recess including making good the damages, colour washing etc as required (RoHS compliant) 2 module moulded plastic box on surface	Nos	2					

8	Item code-90.10.1.3 Supply & Fixing the following types/ sizes of boxes suitable for modular accessories in surface/ recess including making good the damages, colour washing etc as required (RoHS compliant) 3 module moulded plastic box on surface	Nos	2					
9	Item code-1.28.1 Supplying and fixing following Modular base & cover plate on existing modular metal boxes etc. as required. 1 or 2 Module	Nos	2					
10	Item code-1.28.2 Supplying and fixing following Modular base & cover plate on existing modular metal boxes etc. as required. 3 Module	Nos	2					
11	Supplying and fixing following way, horizontal type three pole and neutral, sheet steel, MCB distribution board, 415 volts, on surface / recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) 4 way (4 + 12), Double door	Nos	1					

12	Supplying and fixing following rating, four pole, 415 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. 63 amps	Nos	1				
13	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Double pole	Nos	2				
	Total						
	18% GST						
	Grand total						