

**KANNUR UNIVERSITY**  
(Planning and Development Branch)

**NOTICE INVITING RE-QUOTATIONS**

PLD/E-4/22440/2025

09.01.2026

Sealed competitive Quotations Super scribed as "**UPS Wiring work at Cherussery Auditorium, Thavakkara Campus**" are invited from registered competent Contractors/firms.

Quotations with all details should reach the office of the Registrar, Kannur University, Kannur - 02, on or before 19-01-----2026 at 3 pm and the quotations will be opened at the same day 3.30 pm .

Conditions:

1. The rate quoted should be exclusive of GST and all other charges if any. GST charges and other charges if any should be furnished separately and nothing extra shall be admissible over and above the rate quoted.
2. The contractor shall arrange all material & equipment and should be got approved by the Registrar on recommendations of the Engineer in charge and work shall be executed as per KPWD specifications.
3. The Payment will be made through bank account and no advance payment will be sanctioned
4. Work shall be completed within 30 days from the date of Agreement.
5. The Engineer in Charge shall be Assistant Engineer Electrical.
6. The defect Liability period shall be 18 months from the date of completion of the work. and the contractor shall be responsible to maintain all his works till completion.
7. Successful Quotationer shall deposit a sum equivalent to 5% of value of contract as Security Deposit within the period specified in the Work order.
8. The quotationer, before submitting the quotation for the work shall ensure that, the quotationer visited the Site and satisfied himself about the site conditions for the works (including arranging facilities of water and electricity) and for logistics and smooth flow of workmen, and materials as well as permission from Authorities for this purpose
9. The Contractor shall make his own arrangements of Water and Electricity.
10. Quotation forms and details of works can be had from the [www.kannuruniv.ac.in](http://www.kannuruniv.ac.in).
11. Quotation Schedule is appended.

The Registrar, Kannur University reserves the right to reject any of the quotations or all the quotations without assigning any reason whatsoever.

  
Prof. (Dr.) Joby K Jose

**REGISTRAR  
KANNUR UNIVERSITY  
CIVIL STATION P. O  
KANNUR-670 002**



KANNUR UNIVERSITY							
Quotation schedule for UPS Wiring Work at Cherussery Auditorium,Thavakkara Campus							
LAST DATE OF SUBMISSION:							
SL. NO	ITEM DESCRIPTION	UNIT	QTY	RATE IN FIGURES	RATE IN WORDS	AMOUNT	REMARKS
1	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel/ PVC conduit as required.3 x 2.5 sq. mm	Mtr	20				
2	Supply and laying medium gauge pvc conduit of the following sizes confirming to IS 9537/1983 Part III in roof slab jointing the pipes with forcement PVC solvent cernent, tying & fixing the conduit firmly with the re-inforcement etc. as required.20 mm	Mtr	10				
3	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel/ PVC conduit as required.3 X1.5sq.mm	Mtr	30				
4	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel/ PVC conduit as required.3 x6sq.mm	Mtr	10				
5	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.63 amps	Each	1				

6	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 milli amperes in the existing MCB DB complete with connections, testing and commissioning etc. as required. 63amps	Each	1				
7	Supplying and fixing 5A. to 32 A rating, 240/415 volts, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole	Each	5				
8	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) I2 way, Double door	Each	1				
<b>Total</b>							
<b>18%GST</b>							
<b>Grand total</b>							
(Rupees .....Only)							

**SIGNATURE**

**Name & Address of the Contractor**

**REGISTRAR**

**Date**